



# CERTIFICATE FI/41286

Our Ref. HEL-CERT220100038-01



**Product** Installation conduit of insulating material, rigid

**Type** IRS HF, IRL HF

**Trademark** PM

**Certificate Holder** PM FLEX S.R.L.  
Via XXV aprile 15, 24030, Almenno san Bartolomeo, Bergamo, Italy

**Technical information** Ø16mm, Ø20mm, Ø25mm, Ø32mm, Ø40mm, Ø50mm

**Other information** IRS HF classification code: 2343  
IRL HF classification code: 3343


**The product is certified according to the following standard(s)** EN 61386-1:2008 + A1:2019  
EN IEC 61386-21:2021 + A11:2021

**Validity** This certificate is valid until 2027-01-19 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Date of issue** 2022-01-19

**SGS Fimko Ltd**

**Signature**

  
Joonas Leinonen  
Certification Manager



**SGS Fimko Ltd**

Takomotie 8, FI-00380 Helsinki, Finland  
t. +358 9 696 361 [www.sgs.fi](http://www.sgs.fi)

Business ID 0978538-5

Member of the SGS Group (SGS SA)

**Manufacturer** PM FLEX S.R.L.  
Via XXV aprile 15, 24030, Almenno san Bartolomeo, Bergamo, Italy

**Manufacturing site** Same as manufacturer

**Directive information** The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

**Additional information** The products have certificate No. SE-S-2101637 issued by Intertek Semko AB in accordance with the Nordic Certification Service system.

Non-flame propagating conduits:

- IRS HF: Rigid conduits of white coloured insulating materials
- IRL HF: Rigid conduits of grey coloured insulating materials

Conduits comply with EN 61034-2:2005 test, for low smoke, and no halogen tests according to EN 60754-1:2014 and EN 60754-2:2014 (LSZH).

**As shown in the Test Report(s) No(s):** CV MI16A0656025-01, CV MI16A0655992-01, 2104873STO-001