

CERTIFICATE

Issued to:
Applicant:
P.M. Plastic Material S.R.L.
Via XXV Aprile 15
24030 Almenno San Bartolomeo (BG), Italy

Licensee:
P.M. Plastic Material S.R.L.
Via XXV Aprile 15
24030 Almenno San Bartolomeo (BG), Italy

Product : Conduit system for cable management
Trade name(s) : PM - PROFI FLEX
Type(s)/model(s) : ICTA

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61386-1:2008, EN 61386-22:2004 and EN 61386-22:2004/A11:2010
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2229815

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 5 December 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-105154

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



S. Lehner
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Conduit system for cable management
Trade name(s)	: PM - PROFI FLEX
Type(s)/model(s)	: ICTA
Conduit	: Pliable/self-recovering
Resistance to compression	: 3
Resistance to impact	: 4
Upper temperature classification	: 2
Lower temperature classification	: 2
Resistance to bending	: 3
Colours	: Grey, ivory, green, black and blue
Tested conduits	: 16 mm, 20 mm, 25 mm, 32 mm, 40 mm and 50 mm
Certified conduits	: 16 mm, 20 mm, 25 mm, 32 mm, 40 mm and 50 mm

TESTS**Test requirements**

EN 61386-1:2008

EN 61386-22:2004

EN 61386-22:2004/A11:2010

Test result

The test results are laid down in DEKRA test file 222981500.

Conclusion

The examination proved that all requirements were met.

Factory location

P.M. Plastic Material S.R.L.

Via XXV Aprile 15

24030 Almenno San Bartolomeo (BG), Italy