

CERTIFICATE

No. P17222011





Order No. 329899

Product Conduits for electrical installations

Applicant PM Plastic Materials S.R.L.

15, Via XXV Aprile

24030 Almenno San Bartolomeo (BG)

Italy

PM Plastic Materials S.R.L. Manufacturer

15, Via XXV Aprile

24030 Almenno San Bartolomeo (BG)

PM Plastic Materials s.r.l **Factory**

15, Via XXV Aprile

24030 Almenno San Bartolomeo

Italy

Ratings

Validity

PMTrade mark

Model / Type Ref. **IRS HF**

Rigid conduits of white insulated material. Non-flame propagating conduits. Principal characteristics

Conduit sizes: 16, 20, 25, 32, 40, 50mm. Classification code: 234312-0-010

A sample of the product was tested and found to be in conformity with

INST EN 61386-1:2008

EN 61386-22:2004;A11

This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified

to Nemko for acceptance prior to implementation.

New standards or amendments to the standards may imply that the product design must be

updated and/or that re-testing and re-certification is necessary.

Additional information See page 2

Additional model(s) (1) See page 2

Date of issue 08-05-2017

Nastaran Vadoodi

Certification Department



CERTIFICATE

No. P17222011





Order No. 329899 Page 2 of 2

Additional model(s)

Product Conduits for electrical installations

Pos. No 1

Model / Type Ref. IRL HF

Trade mark (if different from page 1)

Rating

Principal characteristics Rigid conduits of grey insulated material. Non-flame propagating conduits.

Conduit sizes: 16, 20, 25, 32, 40, 50mm. Classification code: 334312-0-010

Additional information Conduits comply with EN 61034-2-:2005 test, for low smoke, and no halogen

tests according to EN 60754-1:2014 and EN 60754-1:2014 (LSZH).

Date of issue 08-05-2017

Nastaran Vadoodi

Certification Department

Nemko AS