



Reference No. SE-S-2101637R1

Conduit for electrical installations

Type designation: IRS HF, IRL HF

Certificate holder: PM FLEX SRL 15, Via XXV Aprile

24030 Almenno San Bartolomeo

Italy

The product complies with

the standard(s):

EN 61386-1:2008+A1

EN IEC 61386-21:2021+A11

Date of expiry: 10 December, 2026

EU Directive information: According to the principle of presumption of conformity, this certificate

constitutes support for an EU Declaration of Conformity to the Low

Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: Date: 11 March, 2022

Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 2



APPENDIX:

Reference No. SE-S-2101637R1

_	•		1 1		
Π.Φ	cnn	1100		ata:	
1 C	CHI	\mathbf{L}		ala.	

Type designation IRS HF
Trademark PM

Test Report2104873STO-001, 2201567STO-001Product informationNon-flame propagating conduits

Rigid conduits of white coloured insulating materials of sizes 16mm, 20mm,

25mm, 32mm, 40mm and 50mm.

Classification code: 2343

Technical Data:

Type designation IRL HF
Trademark PM

Test Report 2104873STO-001, 2201567STO-001
Product information Non-flame propagating conduits

Rigid conduits of grey coloured insulating materials of sizes 16mm, 20mm,

25mm, 32mm, 40mm and 50mm.

Classification code: 3343

Manufacturing Sites: PM FLEX SRL

15, Via XXV APRILE

240 30 ALMENNO, San Bartolomeo (BG)

Italy

Conduits comply with EN 61034-2:2005 test, for low smoke, and no halogen tests according to EN 60754-1:2014 and EN 60754-1:2014(LSZH).

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued S-certificate with ref. No. SE-S-2101637 dated 10 December 2021. A new certificate has been issued on account of changing the name of the manufacturing site.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 11 March, 2022

Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 2